

May 14, 2010

JENSEN BRIDGE & SUPPLY CO.
DAVID SCHMIDS
400 STONEY CREEK DRIVE
PO BOX 151
SANDUSKY MI 48471

Re: Description: PIPES AND FITTINGS, ALUMINIZED STEEL (SEE ALSO STORMWATER DETENTION SYSTEMS)
Manufacturer: JENSEN BRIDGE & SUPPLY CO.
Product Name: CORRUGATED METAL PIPE UNDERGROUND DETENTION SYSTEM
Model Number(s): CORRUGATED PIPE
Product File No: 20100185

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 & 84.40 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2015.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product must conform to American Association of State Highway and Transportation Officials (AASHTO) standard M36/M 36M-90.
- This product may be installed for the following drain and vent use(s):
 - a. Storm sewer gravity flow
- The review undertaken by Commerce staff does not include review and/or approval of this submittal as meeting DNR specifications for ch. NR 151.
- This product is approved for the following use:
 - Stormwater and clearwater subsurface detention system.
- When this product is installed as a subsurface detention system, the installation must be in accordance with the manufacturer's printed instructions. When there is a conflict between the manufacturer's installation instructions and plan approval or product approval stipulations, the plan approval or product approval stipulations will take precedence.

Sizing of piping for stormwater and clearwater subsurface detention shall be made using hydraulic calculations as specified in manufacturer's instructions.

JENSEN BRIDGE & SUPPLY CO.

Page 2

May 14, 2010

- CSP field joints shall be made with a 5-C band with 1/2" X 8" bolts and a 12" wide X 1/4" thick BIDCO gasket.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: jerry.thompson@wi.gov